

WEST VIRGINIA UNIVERSITY
2009 FIRE LOG

AREA	LOCATION	INC NO	DATE	TIME	VALID	CHARGE	MORGANTOWN FIRE DEPARTMENT DESCRIPTION
H	Arnold Apartments	2421	13-Dec-09	656	TRUE	FALSE	Smoke on Eighth Floor as a result of burnt food in apartment 812. Building ventilated via PPV, alarm restored by WVU Fire Control. Units returned to service.
H	Arnold Apartments	1362	16-Jul-09	1359	TRUE	FALSE	Reported as a structure fire, found to be a person trapped in stalled elevator. Subject was in vehicle, stalled between 2nd and 3rd Floor. Subject reported an odor of smoke prior to Fire Department arrival, however, no smoke was located upon removal of person. Slight odor of burnt rubber noticed in elevator shaft. WVU DPS, elevator repair on scene. Access gained to elevator car, subject removed. Elevator car checked, no problems found. Units returned to service.
H	Arnold Apartments	653	29-Mar-09	1753	FALSE	FALSE	False alarm, activated detector on 9th Floor due to burnt food. Alarm restored by maintenance personnel, units returned to service.
H	Arnold Hall	2355	06-Dec-09	313	FALSE	FALSE	Reported fire alarm, found dry chemical extinguisher discharged on 4th Floor and activated 2 detectors, used positive pressure to ventilate powder, Fire Control replaced heads. Alarm reset.
H	Arnold Hall	1723	05-Sep-09	808	FALSE	FALSE	Reported fire alarm at Arnold Hall. No alarm was sounding upon arrival. No reason for response. Cancelled all other units.
H	Arnold Hall	115	17-Jan-09	2226	TRUE	FALSE	Waterline break in the breezeway; shut down valves to control leak, assisted in removal of water, issued a life safety notice mainly to make Ras aware of firewatch procedure. Went over slip fall areas with Ras and Dr. Cory to limit student movement in those areas.
H	Bennett Tower	1769	12-Sep-09	59	TRUE	FALSE	18 year old female difficulty breathing.
H	Bennett Tower	18	05-Jan-09	709	FALSE	FALSE	Reported fire alarm. Upon arrival we were told that steam set off a detector on main floor in bathroom by cleaning personnel. No other hazards. Returned to service.
H	Boreman Hall	2365	08-Dec-09	1818	FALSE	FALSE	Local tamper alarm on a pull station, no alarm actually transmitted.
H	Boreman Hall	881	02-May-09	755	FALSE	TRUE	Fire Control was working on the fire alarm and set it off, they reportedly cancelled us but we did not get cancelled.
H	Boreman Hall	880	02-May-09	615	FALSE	FALSE	Smoke detector set off by dry powder from an extinguisher.
H	Boreman Hall North	1911	02-Oct-09	1210	FALSE	FALSE	False alarm, units cancelled prior to arrival. Returned to service.

WEST VIRGINIA UNIVERSITY
2009 FIRE LOG

AREA	LOCATION	INC NO	DATE	TIME	VALID	CHARGE	MORGANTOWN FIRE DEPARTMENT DESCRIPTION
H	Boreman Hall North	650	29-Mar-09	1046	TRUE	FALSE	False alarm. Residence director accidentally left item on stove, activated smoke detector. Apartment ventilated to remove smoke, units returned to service.
H	Boreman Hall North	1568	18-Aug-09	852	FALSE	FALSE	False alarm, units cancelled prior to arrival.
H	Boreman Hall South	594	19-Mar-09	1857	FALSE	FALSE	Detector activation 2nd Floor.
H	Boreman Hall South	280	06-Feb-09	2118	TRUE	FALSE	Toilet paper and the dispenser set on fire in the mens room. D&L entry used sink water to finish extinguishment. Bathroom Smokey from the plastics burning. Used positive pressure fan to remove smoke and DPS notified and took pictures. Used extinguisher and had to chop bottom of stall divider to put out the fire which had burned into the divider.
H	Boreman Hall South	435	27-Feb-09	1219	FALSE	FALSE	Smoke detector activated in Laundry Area, there was a water leak on the floor in the area this may have caused the activation.
H	Braxton Tower	195	25-Jan-09	2057	TRUE	FALSE	18 year old male difficulty breathing, numbness in arms, assist EMS with patient assessment and stabilization.
H	Braxton Tower	1462	02-Aug-09	621	FALSE	FALSE	Cancelled as we arrived.
H	Braxton Tower	1834	21-Sep-09	757	TRUE	FALSE	19 year old male chest pain, admin 02, took vitals assisted EMS.
H	Brooke Tower	2428	13-Dec-09	2249	FALSE	FALSE	Reported fire alarm. Steam from laundry.
H	Brooke Tower	1959	10-Oct-09	102	TRUE	FALSE	Reported fire alarm, arrival showed moist air from Laundry Room set off smoke detector in hallway.
H	Brooke Tower	1154	05-Jun-09	2030	FALSE	FALSE	Reported fire alarm, water from drain leaked into wiring of a duct detector.
H	Brooke Tower	1666	28-Aug-09	1300	FALSE	FALSE	Reported fire alarm, detector activated for no apparent reason.
H	Brooke Tower	2011	17-Oct-09	449	FALSE	FALSE	Reported fire alarm 8th Floor, cancelled as we were pulling in.
H	Brooke Tower	2140	03-Nov-09	1018	FALSE	FALSE	Alarm reset by Fire Control on our arrival.
H	Dadisman Hall	757	12-Apr-09	914	FALSE	FALSE	Heat detector set off in center section SB Room 14D for no reason.
H	Dadisman Hall	2227	16-Nov-09	156	TRUE	FALSE	Report of an 18 year old male, c/c chest pain. Arrived on scene with MEMS, released from call by MEMS personnel. Returned to service.
H	Dadisman Hall	536	10-Mar-09	844	TRUE	FALSE	Sinkable episode.
H	Dadisman Hall	2286	27-Nov-09	730	FALSE	FALSE	Reported fire alarm: found heat detector basement center storage area activated no apparent reason.

WEST VIRGINIA UNIVERSITY
2009 FIRE LOG

AREA	LOCATION	INC NO	DATE	TIME	VALID	CHARGE	MORGANTOWN FIRE DEPARTMENT DESCRIPTION
H	Dadisman Hall	1064	24-May-09	2016	FALSE	FALSE	Reported fire alarm detector activated Basement Room 14D activated no reason, Fire Control reset and was going to change out detector.
H	Dadisman Hall	185	24-Jan-09	210	FALSE	FALSE	False alarm, units canceled prior to arrival. Returned to service.
H	Dadisman Hall	668	01-Apr-09	253	FALSE	FALSE	Pull station Third Floor North.
H	Dadisman Hall	2476	22-Dec-09	1938	FALSE	FALSE	False alarm, activated heat detector in Basement. Alarm restored by WVU Maintenance personnel. Units returned to service.
H	Dadisman Hall	1704	01-Sep-09	1902	FALSE	FALSE	Scheduled fire drill.
H	Dadisman Hall	1426	28-Jul-09	35	FALSE	FALSE	Detector outside 273 sounding, no apparent reason.
H	Dadisman Hall	157	21-Jan-09	1512	TRUE	FALSE	Supply line on a water closet broke and flooded a bathroom which got water on a detector setting it off. Fire Control silenced alarm and was working on the system and facilities was working on the water.
H	Fieldcrest Hall	1794	15-Sep-09	2316	TRUE	FALSE	Reported fire alarm, found burnt toast.
H	Honors Dorm	1797	16-Sep-09	830	FALSE	FALSE	False alarm.
H	Honors Dorm	1871	26-Sep-09	1018	FALSE	TRUE	Water flow Stair 2 Fourth Floor.
H	Honors Dorm	1787	13-Sep-09	1148	TRUE	FALSE	Elevator rescue. People were out of the elevator upon arrival.
H	Honors Dorm	1613	22-Aug-09	1811	TRUE	FALSE	Detector set off in Room 519 by burnt popcorn.
H	Honors Dorm	2347	05-Dec-09	1634	TRUE	FALSE	Reported fire alarm, found a room smoke detector activated due to resident using hair dryer on her hair.
H	Honors Dorm	1826	20-Sep-09	534	FALSE	TRUE	False alarm, water flow activation on 4th Floor, no apparent cause. Units returned to service.
H	Honors Dorm	1881	28-Sep-09	505	FALSE	TRUE	Reported fire alarm: alarm from Stairwell 2 water flow alarm. Fire Control already on scene and had checked the alarm out. He stated it was the same alarm as Saturday. Alarm reset, units returned.
H	Honors Dorm	1366	17-Jul-09	245	TRUE	FALSE	Water in a smoke detector on the 5th Floor set off alarm.
H	Honors Dorm	1665	28-Aug-09	1249	FALSE	FALSE	Penthouse alarm no apparent reason. No RA met us at the First Street side. Talked to head RA and told them that we would be meeting at First Street side because hookups and Knox Box is there.
H	Lincoln Hall	957	11-May-09	1608	FALSE	FALSE	Reported fire alarm; no alarm sounding upon arrival and maintenance man said that no alarms had sounded.
H	Lincoln Hall	1964	10-Oct-09	1130	TRUE	FALSE	19 year old male flu like symptoms, assist EMS.
H	Lincoln Hall	2085	26-Oct-09	459	TRUE	FALSE	18 year old male difficulty breathing, stated he felt better upon our arrival. Left him with EMS for evaluation.

WEST VIRGINIA UNIVERSITY
2009 FIRE LOG

AREA	LOCATION	INC NO	DATE	TIME	VALID	CHARGE	MORGANTOWN FIRE DEPARTMENT DESCRIPTION
H	Lincoln Hall	2142	03-Nov-09	2258	TRUE	FALSE	Arrived same time as EMS. Patient conscious, alert, waiting in lobby. Released from scene by medic.
H	Lincoln Hall	1130	02-Jun-09	359	FALSE	FALSE	Cancelled before units left station.
H	Lincoln Hall	675	02-Apr-09	1336	TRUE	FALSE	Smell of smoke near Room 242. Nothing found, suspect curling iron or hair straightener. Reset alarm.
H	Lyon Tower	428	25-Feb-09	2229	TRUE	FALSE	Assist EMS with 18 year old female of difficulty breathing, nausea.
H	Lyon Tower	1936	06-Oct-09	940	TRUE	FALSE	Reported smoke on the Second Floor. Found overloaded washing machine, belt problem.
H	Lyon Tower	1213	20-Jun-09	211	FALSE	FALSE	Smoke detector no apparent reason.
H	Lyon Tower	1215	20-Jun-09	503	TRUE	FALSE	WVU Fire Control indicated a water leak on the Ninth Floor caused a duct detector to malfunction.
H	Lyon Tower	1260	27-Jun-09	1110	FALSE	TRUE	Pull station activated by resident, malicious.
H	Lyon Tower	24	07-Jan-09	705	FALSE	FALSE	Fire alarm.
H	Lyon Tower	767	15-Apr-09	1135	TRUE	FALSE	Reported fire alarm, burnt food in microwave.
H	Lyon Tower	1792	15-Sep-09	1050	FALSE	FALSE	Reported fire alarm, smoke detector activated due to high humidity from a clother dryer.
H	Lyon Tower	1236	22-Jun-09	2119	FALSE	TRUE	Smoke detector set off on the First Floor. No fire.
H	Medical Center Apartments	723	06-Apr-09	2045	TRUE	FALSE	21 year old female syncopal, difficulty , refused transport.
H	Phi Kappa Phi	875	02-May-09	309	FALSE	FALSE	Smoke detector set off in main living area for no reason. Staff 2 and 9 called to the scene due to trash in hallways, rooms, and a blocked exit.
H	Phi Kappa Phi Fraternity	400	21-Feb-09	2219	FALSE	FALSE	False alarm, activated detector on Second Floor Hallway, no apparent cause. Alarm restored by WVU maintenance, units returned to service.
H	Pi Kappa Phi Fraternity	769	16-Apr-09	118	TRUE	FALSE	Reported fire alarm at the Pi Kappa Phi. Burnt food in the microwave.
H	Pi Kappa Phi Fraternity	696	04-Apr-09	55	FALSE	FALSE	Alarm set off by smoking in the building.
H	Pi Kappa Phi Fraternity	786	18-Apr-09	238	FALSE	TRUE	Activated alarm system due to subjects smoking on Second Floor. No one available to restore alarm system. Alarm reset, units returned to service.
H	Pi Kappa Phi Fraternity	788	18-Apr-09	405	FALSE	TRUE	False alarm, subjects smoking on Third Floor activated alarm system. Building checked, two citations issued for failure to comply, two citations issued for tampering with alarm system.
H	Pi Kappa Phi Fraternity	547	11-Mar-09	1537	TRUE	FALSE	Reported fire alarm found 2 detectors activated due to cooking.
H	Pierpont Apartments	1194	16-Jun-09	840	FALSE	FALSE	Cancelled before leaving station.
H	Pierpont Apartments	1403	23-Jul-09	1414	FALSE	TRUE	Reported fire alarm, cancelled enroute.

WEST VIRGINIA UNIVERSITY
2009 FIRE LOG

AREA	LOCATION	INC NO	DATE	TIME	VALID	CHARGE	MORGANTOWN FIRE DEPARTMENT DESCRIPTION
H	Pierpont Apartments	1842	22-Sep-09	707	FALSE	TRUE	Alarm was from steam, Room 511. Alarm was mistakenly reset before FD arrival. Informed RA's of proper protocol.
H	Pierpont Apartments	1759	10-Sep-09	1744	FALSE	FALSE	Smoke detector being used as a cooking timer. Accidental activation.
H	Pierpont Apartments	1286	01-Jul-09	1216	FALSE	FALSE	Cancelled before arrival.
H	Pierpont Apartments	9	02-Jan-09	1005	FALSE	FALSE	Reported fire alarm at Pierpont Apartments. Cancelled in route.
H	Pierpont Apartments	787	18-Apr-09	310	FALSE	TRUE	Steam from shower set off detector in Room 203.
H	Pierpont Apartments	188	24-Jan-09	1514	FALSE	TRUE	Cooking set off smoke detector.
H	Pierpont Apartments	1045	22-May-09	1827	FALSE	TRUE	Smoke detector First Floor Hallway, nothing found.
H	Pierpont Apartments	1252	25-Jun-09	1918	FALSE	TRUE	Dispatched and cancelled enroute.
H	Pierpont Apartments	815	21-Apr-09	1850	FALSE	TRUE	Reported fire alarm, steam from cooking set off alarm.
H	Pierpont Apartments	1167	09-Jun-09	2105	FALSE	FALSE	Cancelled enroute.
H	Pierpont Apartments	1605	22-Aug-09	147	FALSE	FALSE	Alarm reset by RAC, informed manager they are not to reset without our approval.
H	Pierpont Apartments	1785	13-Sep-09	1051	FALSE	TRUE	Cooking in 913, not even burnt food.
H	Pierpont Apartments	921	07-May-09	715	FALSE	FALSE	Reported fire alarm. Burnt toast.
H	Pierpont Apartments	2168	08-Nov-09	144	TRUE	FALSE	Reported fire alarm. Burnt popcorn activated alarm.
H	Pierpont Apartments	842	25-Apr-09	2226	FALSE	FALSE	Cancelled before leaving station.
H	Pierpont Apartments	1273	29-Jun-09	1159	TRUE	FALSE	Extremely burnt food in the microwave, lots of smoke, no fire. Helped clear smoke, reset alarm.
H	Pierpont Apartments	739	09-Apr-09	623	FALSE	FALSE	Smoke detector in vending area, no apparent reason, alarm reset, advised them to have maintenance look at the detector.
H	Pierpont Apartments	2058	22-Oct-09	1549	FALSE	TRUE	Responded from Station 1, cancelled enroute.
H	Pierpont Apartments	341	13-Feb-09	238	TRUE	FALSE	Burnt food in microwave Room 805.
H	Pierpont Apartments	350	14-Feb-09	1145	TRUE	FALSE	Toned for alarm, MECCA advised burnt food; other units cancelled, CO. 3 responded to scene. Burnt french toast on the 6th Floor.
H	Pierpont Apartments	413	23-Feb-09	1033	TRUE	FALSE	Burnt food 8th Floor, alarm cleared, no fire.
H	Pierpont Apartments	1388	21-Jul-09	856	FALSE	FALSE	Cancelled before units left station.
H	Pierpont Apartments	292	08-Feb-09	458	FALSE	FALSE	Reported fire alarm.
H	Pierpont Apartments	2096	28-Oct-09	1914	TRUE	FALSE	Reported structure fire Room 115. Found a plastic dish drainer had been left on stove. No fire on our arrival. Staff had discharged dry chem extinguisher prior to our arrival. Checked cabinets above stove. Used ppv fan from L-1 to vent hall and room.
H	Pierpont Apartments	610	23-Mar-09	1039	FALSE	FALSE	Reported fire alarm, cancelled enroute.
H	Pierpont Apartments	2120	31-Oct-09	1134	TRUE	FALSE	Burned bacon, Room 611. No fire.

WEST VIRGINIA UNIVERSITY
2009 FIRE LOG

AREA	LOCATION	INC NO	DATE	TIME	VALID	CHARGE	MORGANTOWN FIRE DEPARTMENT DESCRIPTION
H	Pierpont Apartments	1970	11-Oct-09	900	TRUE	FALSE	Reported fire alarm, bacon cooking set off detector in living room.
H	Pierpont Apartments	1874	26-Sep-09	2218	FALSE	TRUE	Reported fire alarm, steam set off detector.
H	Pierpont Apartments	1943	07-Oct-09	2104	FALSE	FALSE	Smoke detector set off for no reason.
H	Sigma Alpha Epsilon	101	17-Jan-09	122	FALSE	TRUE	Reported fire alarm cancelled enroute.
H	Sigma Alpha Epsilon	2038	20-Oct-09	1457	TRUE	FALSE	Steam from cooking set off alarm.
H	Sigma Alpha Epsilon	161	22-Jan-09	508	FALSE	TRUE	Pull station pulled on the Second Floor. No one available to reset alarm. Alarm was silenced and a life safety warning issued so that a fire watch would be established.
H	Sigma Alpha Epsilon	1635	24-Aug-09	2027	FALSE	FALSE	Cancelled before arriving on scene.
H	Sigma Alpha Epsilon	55	12-Jan-09	237	FALSE	FALSE	Alarm system activation no fire.
H	Sigma Alpha Epsilon	2373	09-Dec-09	1445	FALSE	FALSE	Reported fire alarm, detector set off by spray painting, reset alarm and returned.
H	Sigma Alpha Epsilon	2429	14-Dec-09	112	FALSE	TRUE	Unfound alarm reset by house leader.
H	Sigma Alpha Epsilon	2059	22-Oct-09	1606	TRUE	FALSE	Reported fire alarm: cook set off detector in dining area. System reset.
H	Sigma Alpha Epsilon	166	22-Jan-09	1017	FALSE	TRUE	Alarm activated by worker while working on alarm system.
H	Sigma Alpha Epsilon	177	23-Jan-09	839	FALSE	TRUE	False alarm, activated detector in downstairs game room as a result of cleaning personnel sweeping floor. Alarm to be restored by Fire Control. Units returned to service.
H	Spruce House	2469	21-Dec-09	1152	FALSE	FALSE	Dialer alarm was going off.
H	Stalnakar Hall	618	23-Mar-09	2000	FALSE	FALSE	Butt Receptacle smoking in front of air intake.
H	Stalnakar Hall	142	20-Jan-09	857	FALSE	TRUE	False alarm, activated detector - no apparent cause. System restored by WVU Fire Control. Units returned to service.
H	Stalnakar Hall	2044	21-Oct-09	1555	TRUE	FALSE	Assist EMS with this person.
H	Stalnakar Hall	1896	01-Oct-09	1145	FALSE	FALSE	Reported fire alarm detector activated no reason.
H	Stalnakar Hall	261	03-Feb-09	1425	TRUE	FALSE	Aid given to 47 year old female with chest pains; transferred care to MEMS.
H	Stalnakar Hall	1150	05-Jun-09	406	TRUE	FALSE	40 year old male, c/c chest pain. MEMS arrived on scene immediately following FD arrival, assisted in patient evaluation, loading. Returned to service.
H	Stalnakar Hall	2214	14-Nov-09	1215	FALSE	FALSE	Reported fire alarm cancelled en route.
H	Stalnakar Hall	137	19-Jan-09	1627	FALSE	FALSE	Smoke detectir Third Floor no apparent reason.
H	Stalnakar Hall	1006	18-May-09	903	FALSE	FALSE	False alarm, units cancelled prior to arrival. Returned to service.
H	Stalnakar Hall	2212	14-Nov-09	722	FALSE	TRUE	False alarm, units cancelled prior to arrival by alarm company. Returned to service.H
H	Stalnakar Hall	1460	01-Aug-09	2219	FALSE	FALSE	Reported fire alarm smoke detector 1st Floor South.

WEST VIRGINIA UNIVERSITY
2009 FIRE LOG

AREA	LOCATION	INC NO	DATE	TIME	VALID	CHARGE	MORGANTOWN FIRE DEPARTMENT DESCRIPTION
H	Stalnakner Hall	1514	11-Aug-09	906	TRUE	FALSE	Reported fire alarm, smoke detector activated in Kitchen area. We were dispatched to Dadisman Hall. The alarm was at Stalnakner.
H	Stalnakner Hall	1521	12-Aug-09	1138	TRUE	FALSE	Flase alarm, activated detector on Second Floor center as a result of cleaning activities. Area checked, alarm restored by WVU Fire Control personnel, units returned to service.
H	Stalnakner Hall	1524	12-Aug-09	1905	FALSE	TRUE	False alarm, activated detector on First Floor South. Area checked, alarm restored by maintenance group. Units returned to service.
H	Stalnakner Hall	2430	14-Dec-09	412	TRUE	FALSE	Pop off valve on hot water tank sent steam out and set off detector.
H	Stalnakner Hall	1706	01-Sep-09	2034	FALSE	FALSE	Scheduled fire drill.
H	Stalnakner Hall	2150	05-Nov-09	1020	FALSE	FALSE	Cancelled while en route.
H	Summit Hall	1926	04-Oct-09	2237	TRUE	FALSE	19 year old male c/c difficulty breathing, chest pain. Patient had consumed an energy drink prior to call. MEMS arrived on scene with FD, R-1 returned to service after services no longer needed.
H	Summit Hall	1705	01-Sep-09	1952	FALSE	FALSE	Scheduled fire drill, issued LSN for the alarm horns and strobes not working on Floors 6-7-8.
H	Summit Hall	243	01-Feb-09	421	FALSE	FALSE	Someone discharged a dry chemical extinguisher in the 10th Floor Study Room activating the smoke detector. WVU DPS thought they might have a suspect. They are going to contact Capt. Tennant about charges.
H	Summit Hall	2403	10-Dec-09	1330	TRUE	FALSE	Maintenance person lost valve while working, causing heating water to escape on 8th Floor, flooding rooms and hallway on 8th and 7th Floors. WVU Maintenance was on scene, waiting for water to drain down so that they could replace valve.
H	Summit Hall	1375	18-Jul-09	1204	TRUE	FALSE	Small gas leak in line in kitchen under renovation. Turned off main gas line.
H	Summit Hall	2511	30-Dec-09	859	FALSE	FALSE	Reported fire alarm cancelled enroute.
H	Summit Hall	889	03-May-09	50	TRUE	FALSE	Assist EMS.
H	Summit Hall	1926	04-Oct-09	2237	TRUE	FALSE	Reported fire alarm; workmen core drilling on the Sixth Floor and set off detector.
H	Summit Hall	919	07-May-09	243	FALSE	FALSE	Reported fire alarm.
H	Summit Hall	1239	23-Jun-09	1418	FALSE	FALSE	Reported fire alarm, cancelled enroute.